



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 01/01/2026

Area: CHP

Equipment	Job
JH C 1 , C 3	Hoist and LDB panels maintenance was done
LC 2 to LBDS 1	Cable continuity checked and found ok
CC 113	BRS sensors replaced and kept in ckt
JH C212	Burnt sump pump removed and submersible pump provided
S 2	5 nos 30W LED fixtures provided
Coal complex	Rooms cleaning done
SCR 6	Damaged cable trays welded and cable dressing done.LT end limit sensor replaced and tested