



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 17/05/2025

Area: OHP

| Equipment | Job |
|--------------------|---|
| CO-8A,DB-1,37A | MOTOR, PANEL , CJD PPM IS DONE. |
| HT COUPLERS | SPACE HEATERS INSPECTION IS DONE. |
| WOBR-1,2,3 | B/W MOTOR INSPECTION IS DONE. |
| TBS-1 ON CO-21 | PCRD MOTOR IS REPLACED WITH SPARE ONE, REMOVED MOTOR SHIFTED TO HVMCC-1 AND COUPLING REMOVED. |
| TBS-5 ON CO-23 | PPM IS DONE |
| CO-16A,16B,17A,17B | MOTOR, PANEL , FIELD DEVICES PPM IS DONE. INDICATION LAMPS CHANGED FOR CO-16A BRS MODULE. |
| CO-5,6 TUNNEL | ILLUMINATION IS IMPROVED. |
| JH O-3 | LDB PPM IS DONE |