



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 21/01/2026

Shift: A

Incharge(s): Amit Roy

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|---------------|---|--|----------|----------|---------|
| 1 | OHP | CO-6A | ZSS acting | Probe cable got cut.Rejoint done and tested okay | 07:30:00 | 07:45:00 | |
| 2 | OHP | WOBR on CO-26 | Slewing towards CHP side not taking place | Limit handle removed and tested okay | 07:00:00 | 07:20:00 | |
| 3 | OHP | BRC on CO-33M | LT not taking place | PCRD tension acted.Released and tested okay | 08:45:00 | 09:00:00 | |
| 4 | OHP | BRC on CO-28 | CT not taking place | Drive tripped.Reset done | 10:05:00 | 10:15:00 | |
| 5 | OHP | CO-85 | Reported tripped | OLR acted.Reset done | 10:15:00 | 10:25:00 | |
| 6 | OHP | CO-33M | Reported tripped | OLR acted.Reset done | 13:40:00 | 13:50:00 | |
| 7 | CHP | CC-37 SCR-7 | Luff up not taking place | Limit acted.Released and tested okay | 06:35:00 | 06:45:00 | |
| 8 | CHP | CC-32 SCR-5 | LT not taking place | Drive tripped.Reset done | 06:50:00 | 07:05:00 | |
| 9 | CHP | Cc-40 SCR-2 | Slewing not taking place | Wrong complaint | 09:25:00 | 09:35:00 | |
| 10 | CHP | Cc-107 | Reported tripped | OLR acted.Reset done | 10:12:00 | 10:20:00 | |
| 11 | CHP | CC-112 SCR-8 | Slewing not taking place | Limit acted.Released and tested okay | 11:05:00 | 11:20:00 | |
| 12 | CHP | Cc-108 | Reported tripped | OLR acted.Reset done | 11:40:00 | 11:50:00 | |
| 13 | WT | OP-5 | Reported tripped | D-2 tripped.Reset done | 13:05:00 | 13:15:00 | |



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 21/01/2026

Incharge(s): Amit Roy

Shift: A

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|--------------|-----------------------|------------------------------|----------|----------|---------|
| 14 | WT | OP-1 to OP-6 | Communication problem | PLC recycled and tested okay | 08:55:00 | 09:00:00 | |