



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 01/09/2025

Area: WT

Equipment	Job
MIS	Coupling fixed to 37 KW spare motor and End cover bolts found loose,tightening done
OT 1	In LDB, lug replaced to neutral cable and tightening done
OP 10	control circuit checked and lighting improved
OP 1	After rake maintenance done