



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 28/01/2026

Shift: B

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	VS-4A	Reported tripped	OLR acted.Reset done	15:15:00	15:25:00	
2	OHP	BRC on CO-8A	Reported no drives working	SPP acted.Reset done	17:00:00	17:15:00	
3	OHP	BRC on CO-28	Reported yard interlock missing	Wrong complaint	17:10:00	17:25:00	
4	CHP	CC-131	Reported tripped	OLR acted.Reset done	18:00:00	18:05:00	
5	CHP	Cc-54	Reported tripped	OLR acted.Reset done	19:40:00	19:45:00	
6	CHP	LC-13(feeder-2)	Tripped	Due to earth fault.Reset done	17:40:00	17:50:00	
7	CHP	RG-2 F/G	Reported tripped	OLR acted.Reset done	15:30:00	15:40:00	
8	CHP	CC-40 SCR-2	B/C not working	Signal issue from CPP side.	19:50:00	19:55:00	
9	CHP	CC-223	Conveyor not running	Drive tripped.Reset done(2 times)	20:05:00	21:10:00	
10	WT	Air compressor	Reported not working	I/C 125A(2 nos.) fuses blown.Replaced and tested okay	17:15:00	17:30:00	
11	WT	CO-3(C/D)	Reported reverse movement not taking place	Checked and found internal loop missing.Loop provided from RL-5 to RI-9 and tested okay	20:00:00	22:20:00	NO electrical delay.
12	IOSA	TBS	LT not taking place	M-4 gearbox problem.Motor disconnected and tested okay	14:00:00	17:30:00	