



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 26/04/2025

Shift: C

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 6a	olr acted	reset it done	23:00:00	23:10:00	
2	OHP	Co 35	OLr acted	reset it done	22:35:00 23:45:00	22:40:00 23:50:00	
3	CHP	CC 39 scr 7	slew not working,coling fan mpcb trips	made it on	23:00:00	23:15:00	
4	CHP	CC 104 SCR 9	slew not working,mpd trips in ol	reset it done	02:30:00	02:45:00	
5	CHP	CC 39 SCR 7	Lt not working,OT acted	released it	05:00:00	05:10:00	
6	CHP	CC 132	trips due to olr	reset it done	00:50:00 04:30:00	00:55:00 04:35:00	
7	CHP	CC 52	ZSS acted due to load	informed operation	03:00:00	03:05:00	
8	CHP	CC 40 SCR6	B/C not running , control mcb trips,motor power cable damaged	control ckt checked,mcb trips, made it on than cmd given immediately mccb trips,megger done @panel side one phase open,megger done @ motor TB side all ok value,spare core used lugging done and termination done,given clearance	03:00:00	05:50:00	check the damaged cable near slew chamber