



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 05/05/2025

Area: IOSA

| Equipment | Job |
|-----------|---|
| OC-19A | |
| | |
| UPS | CABLE (16 SQMM , 4 CORE) BROUGHT FROM MANUAL CRUSHING YARD (2B) TO LC-2. CABLE LAYED BETWEEN OM-5, 6 AND BATTERY BANK TO UPS PANEL. |

UPS & BATTERY CHARGER