



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 29/05/2025

Area: CHP

Equipment	Job
CC 33	Module out going power finger contacts replaced
CC 31	Motor TB cover fixed
SCR 5	PCRD guide adjusted and cable winding done
CC 37,111,112,SCR 8,S3,201,202,203,204,205,206	PPM was done
SCR4,SCR 8	Running inspection was done