



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 19/02/2026

Area: WT

Equipment	Job
OP 10	Trolley line checked from maintenance zone to Tippler end found OK
OP 10	D B R room sheets closed all sides (welding to be done)
OP 10	AC control panel fixed inside D B R room
OP 10	Forward End Limit and striker installed and tested
OP 10	control cable laid from Forward Limit Switch to C J B and connected to identified cores
MIS	1.2 sq mm 4 pair screen cable received from Utility Dept.
OP 1,3 and 6	After rake maintenance done