



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 04/02/2026

Area: WT

| Equipment | Job |
|----------------|--|
| OT 3 | M2 ,burnt motor coupling removed and sent to E R S |
| OP 5 | Track lifting done by railways @ parking zone |
| CP 3 jobs | Control Desk side wiring done ,trolly line inspection done from C D found signals OK |
| CP 1,2 and 4 | After rake maintenance done |
| OP 1,4,5 and 8 | After rake maintenance done |