



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 15/02/2026

Shift: B

Incharge(s): Nagendra Midde

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|------------------------------|---|-------------------|----------|----------|---------|
| 1 | OHP | BRC ON CO 31 LT | SELECTOR SWITCH IN LOCAL | CHANGED TO REMOTE | 16:45:00 | 17:00:00 | |
| 2 | OHP | TBS ON CO 5A LT NOT STOPPING | FWD PB GOT STUCK | MADE IT FREE | 18:20:00 | 18:30:00 | |
| 3 | OHP | BRC ON CO 28 | CT DRIVE TRIPPED | RESET | 20:00:00 | 20:20:00 | |
| 4 | CHP | CC 27 A POSITION ON CC 39 | SENSOR PLATE BENT | ADJUSTED PROPERLY | 14:30:00 | 14:45:00 | |
| 5 | CHP | CC 51 | FEEDING CON OLR ACTED | RESET | 16:15:00 | 20:00:00 | 4 TIMES |
| 6 | CHP | CC 117 | OLR ACTED | RESET | 17:30:00 | 17:45:00 | |
| 7 | CHP | CC 216 | OLR ACTED | RESET | 14:25:00 | 14:30:00 | |
| 8 | CHP | SCR 7 ON CC 104 | ACB TRIP IS OPERATED IN IN OPERATOR CABIN | ACB MADE ON | 15:35:00 | 15:45:00 | |
| 9 | CHP | SCR 7 ON CC 104 LT | PCRD O/T ACTED | RELEASED | 17:05:00 | 17:15:00 | |
| 10 | CHP | CC 31 | OLR ACTED | RESET | 18:15:00 | 19:10:00 | 3 TIMES |
| 11 | CHP | CC 108 | OLR ACTED | RESET | 20:15:00 | 20:20:00 | |