



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 12/05/2025

Area: OHP

Equipment	Job
CO-3A	Spare motor shifted to CO-3A H/E
CO-12A,CO-17	Lighting done
CR-1A,2A	Motor PPM done
RSCO-1A	Selector switches provided instead of toggle switches for position indication and tested okay
WOBR-2 ON CO-25	B/W Motor base welding done
BPC-1,2,JH-14,CO-27A,CO-30,CO-31	Dist PPM done
TBS-7 on CO-19	BCH brake panel changing done and tested okay
BRC-2 ON Repair Bay	22KW CT motor termination removal done
BRC-1 on CO-32,CO-32	PPM done
WOBR-2	Shifted from CO-6A to CO-25
WOBR-4	Shifted from CO-25 to CO-6A