



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 07/01/2026

Incharge(s): K SANKARA RAO

Shift: A

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|---------------|---|---------------------------------------|----------------------|----------------------|---------|
| 1 | OHP | brc on co-31 | B/C TRIPPED ON OLR | RESET DONE | 06:50:00 | 07:05:00 | |
| 2 | OHP | CO-34 | OLR ACTED | RESET DONE | 09:00:00 | 09:10:00 | |
| 3 | OHP | CO-34 | REPORTED C/S ACTED | SENSOR CLEANED THAN RESET DONE OK | 09:15:00 | 09:30:00 | |
| 4 | OHP | BRC ON CO-28 | REPORTED B/W S NOT RUNNING | FAULT RESET IN OPERATOR CABIN THAN OK | 09:35:00 | 09:50:00 | |
| 5 | OHP | CO-29 | OLR ACTE4D | RESET DONE | 09:45:00 | 09:50:00 | |
| 6 | CHP | CC-26 | TRIPPED ON OLR | RESET DONE | 06:33:00 | 06:40:00 | |
| 7 | CHP | TT ON CC-28 | REPORTED LT NOT TAKING PLACE MPCB TRIP | MADE ON THAN OK | 11:00:00 | 11:10:00 | |
| 8 | CHP | CC-131 | OLR ACTED (2TIMES) | RESET DONE | 11:30:00 13:10:00 | 11:35:00 13:15:00 | |
| 9 | CHP | CC-51 | MPD ACTED (20 TIMES)FEEDING CONVEYOR STOPPED | RESET DONE | 06:50:00 | 13:15:00 | |
| 10 | CHP | CC-34 SCR-1 | REPORTED B/W NOT RUNNING | WRONG COMPLAINT | 07:50:00 | 08:00:00 | |
| 11 | IOSA | BRC ON OC-15A | REPORTED LT NOT TAKING PLACE FOUND SKEW LIMIT DAMAGED | SKEW ADJUSTED LIMIT BYPASSED | 08:30:00 | 09:45:00 | |