



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 27/12/2025

Incharge(s): K SANKARA RAO

Shift: A

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|---------------|--|--|----------|----------|--|
| 1 | OHP | CO-77 | TRIPPED ON OLR | RESET DONE | 06:20:00 | 06:25:00 | |
| 2 | OHP | VS-3 | OLR ACTED | RESET DONE | 07:20:00 | 07:25:00 | |
| 3 | OHP | TIS ON CO-29 | BELT STOPPING ON ZSS FOUND IRON PIECE STUCK UP | REMOVED THAN OK | 10:45:00 | 10:55:00 | |
| 4 | OHP | WOBR ON CO-6A | B/C AND LUFFING NOT WORKING DUE TO MATERIAL JAMMING | INFORMED TO OPERATION AND MECHANICAL | 07:00:00 | 07:10:00 | |
| 5 | CHP | CC-117 | OLR ACTED | RESET DONE | 11:10:00 | 11:20:00 | |
| 6 | CHP | CC-33 SCR3 | REPORTED B/C NOT RUNNING OLR ACTED | RESET DONE THAN OK | 12:45:00 | 12:55:00 | |
| 7 | CHP | CC-104 SCR-9 | REPORTED B/C STOPPING FREQUENTLY CHECKED AND FOUND ZSS CAGE STUCK UP | TEMPORARY ZSS BYPASSED AND GIVEN CLEARANCE | 12:15:00 | 12:30:00 | ZSS CAGE AND PROBE REPLACED WITH NEW AT 1345HRS BYPASS REMOVED |
| 8 | WT | OT-1 | DRIVE -1 PGF-1 FAULT TRIP | RESET DONE | 07:20:00 | 07:30:00 | |