



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 25/12/2025

Shift: C

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WBR ON CO 26	SLEW DRIVE TRIPPED	RESET	23:25:00	23:40:00	
2	OHP	CO 26	OLR ACTED	RESET	03:40:00 04:30:00	03:50:00 04:40:00	
3	OHP	CR 3	6.6KV/230V CONTROL TRANSFORMER FUSES TIPS GOT MELTED	230V SUPPLY GIVEN FROM I/O RACK	23:30:00	00:40:00	
4	OHP	VS 1A	OLR ACTED	RESET	01:20:00	01:25:00	
5	OHP	CR 3	RAT FELL IN INCOMER AND INCOMER TRIPPED IN LBDS 5	REMOVED AND CHARGED CHECKED AND GIVEN CLEARENCE	04:40:00	05:20:00	
6	CHP	CC 51	FEEDING CONV MPD TRIP	RESET	23:40:00	04:00:00	3 TIMES
7	CHP	CC 52	FEEDING CONV MPD ACTED	RSEEST	05:40:00	05:45:00	
8	CHP	CC 54	OLR ACTED	RESET	22:45:00	03:00:00	9 TIMES
9	CHP	CC 131	OLR ACTED	RESET	01:40:00	01:45:00	
10	CHP	CC 117	OLR ACTED	RESET	01:00:00	05:10:00	3 TIMES
11	CHP	R1 ON CC 33	INTERLOCK CAGE STUCK	MADE IT FREE	01:10:00	01:30:00	
12	CHP	CC 201, 203	OLR ACTED	RESET	01:35:00	01:45:00	
13	WT	OP2	BREAKER TRIPPED	MADE IT ON	05:00:00	05:10:00	