



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 26/11/2025

Area: IOSA

| Equipment | Job |
|-------------------|--|
| OJH-4B | PPM DONE ON ELECTRICAL HOIST AT OC-7C TAILEND. |
| BLENDER RECLAIMER | BRIDGE CONVEYOR PULLCHORD BASE GOT DAMAGED. REPLACED THE SWITCH AND TRIAL RUN TAKEN. |
| OC-13A | PULL CHORD HARDWARE SIGNAL NOT COMING. CHECKED AND RECTIFIED AND SAME AND REMOVED BYPASS. |
| WOBR-LnT | MAINTENANCE DONE ON SLIPRING ASSEMBLY , TRANSFORMER HT AND LT SIDE TERMINATION. |
| OC-36A | LIGHTING DEFECTS RECTIFICATION IS IN PROGRESS. ONE LIGHT FITTING PROVIDED NEW HEAD END AREA. |