



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 19/10/2025

Incharge(s): Nagendra Midde

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC ON CO 31	B/C OLR ACTED	RESET	16:50:00	17:05:00	
2	OHP	CO 29	OLR ACTED	RESET	17:15:00 19:25:00 20:50:00	17:25:00 19:30:00 21:00:00	
3	OHP	CO 26	OLR ACTED	RESET	18:00:00 19:25:00	18:10:00 19:35:00	
4	CHP	CC 107	OLR ACTED	RESET	16:40:00	16:45:00	
5	CHP	SCR 6 ON CC 38	DRIVE TRIPPING FREQUENTLY DUE TO F30002 AND EXCESSIVE HEATING	FAN PLACED INFRONT OF THE PANEL AND DECELERATION TIME INCREASED FROM 6 SEC TO 10 SEC	18:00:00	20:00:00	
6	CHP	CC 26	F/G OLR ACTED	RESET	14:30:00	14:40:00	
7	WT	OT1	DRIVE 1 TRIPPED	RESET	16:50:00	17:00:00	
8	WT	OP6 NOT MOVING	INCOMER TRIPPING FREQUENTLY DUE TO TOP C CLAMP AND U CLAMP BENT	TO BE CHECKED	21:30:00	22:00:00	