



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 07/08/2025

Incharge(s): Saurabh Kumar Yadav

Shift: B

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|-----------|--|--------------------|----------|----------|---|
| 1 | OHP | Co 26 | olr acted | reset | 18:00:00 | 18:10:00 | |
| 2 | OHP | VF 10 A | reported red,drive trip in overload | reset | 17:20:00 | 17:30:00 | |
| 3 | OHP | CO 35 | olr acted | reset | 20:00:00 | 20:10:00 | |
| 4 | OHP | CO 87 | olr acted | reset | 19:30:00 | 19:35:00 | |
| 5 | CHP | cc113 | zss acted, due to jamming | informed operation | 16:30:00 | 16:35:00 | |
| 6 | CHP | cc 51 | olr acted | reset | 15:45:00 | 15:50:00 | |
| 7 | CHP | CC 114 | zss acted due to jamming | informed operation | 16:40:00 | 16:50:00 | |
| 8 | CHP | CC 31 R1 | b/c not running,zss interlock cage stucked | cage made free | 20:15:00 | 20:30:00 | |
| 9 | CHP | cc 107 | olr acted | reset | 21:00:00 | 21:10:00 | |
| 10 | IOSA | sco 1A | olr acted | reset | 16:45:00 | 16:50:00 | |
| 11 | IOSA | new WOBR | SLEW NOT TAKING PLACE,right limit acted | limit released, | 21:40:00 | 22:00:00 | still not slewing working,work going on |