



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 28/09/2025

Incharge(s): Saurabh Kumar Yadav

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	wobr on co 26	slew not taking place ,drive trips	reset	10:20:00	10:40:00	
2	OHP	brc on co 32	bc olr acted	reset	09:50:00	10:05:00	
3	OHP	co 26	olr acted	reset	10:40:00	10:45:00	
4	OHP	RSCO 1A(B)	mpcb tripped, due to jamming	made it on	07:27:00	07:35:00	
5	OHP	CO 111(b)	mpcb tripped ,stone stucked in belt	made on,informed operation	12:40:00	12:45:00	
6	CHP	CC 31 SCR4	B/W not running,b/w stucked	all electrical control checked found ok even after generating output in xmd also b/w gave little jerk only,informed mech than they did it manually	10:00:00	10:35:00	
7	CHP	CC 105 SCR10	BC not running,mpr tripped in ol,jamming is there	mpr reset,informed operation	08:15:00	08:35:00	
8	CHP	CC 45	olr acted	reset	09:25:00	09:30:00	
9	CHP	CC 18	Emergency PB acted,pb base got open	properly connected	08:00:00	08:10:00	
10	CHP	CC 51	mpd trips feeding conveyor	reset	08:00:00	08:05:00	
11	CHP	CC 54	trips in olr	reset	13:30:00	13:35:00	
12	WT	OT 2 D2	trips in ovr fault	reset it done	10:35:00	10:40:00	