



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 10/01/2026

Incharge(s): Lal Singh,Lal Singh

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-12	ZSS PROB DAMAGED	REPLACED	04:00:00	04:15:00	
2	OHP	AF-4	TRIPPED ON SPEED DEVIATION FAULT	RESET DONE	01:35:00	01:40:00	
3	OHP	BRC ON CO-28	CT NOT WORKING	RESET DONE	03:40:00	03:55:00	
4	CHP	CC-43	TRIPPED ON OLR	RESET DONE	02:55:00	03:10:00	
5	CHP	CC-114	TRIPPED ON OLR	RESET DONE	00:55:00	01:05:00	
6	CHP	CC-51	MPD TRIPED	RESET DONE	03:25:00	03:30:00	
7	CHP	CC-51	TRIPPED ON OLR	RESET DONE	04:30:00	04:35:00	