



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 29/12/2025

Incharge(s): Amit Roy

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TT-2 on CO-22	Reported position indication not coming	Wire came out of TB.Connected properly	15:00:00	15:15:00	
2	OHP	Stacker on CO-7A	LT not taking place	Boom reclaiming height not reached.Boom placed properly and tested okay	20:00:00	20:15:00	
3	CHP	Cc-201	Reported tripped	OLR acted.Reset done	14:45:00	14:55:00	
4	CHP	CC 203	P/C acted	Released and tested okay	14:45:00	14:55:00	
5	CHP	CC-32	Reported tripped	OLR acted.Reset done	17:30:00	17:35:00	
6	CHP	CC-33 SCR-3	B/C not running	OLR acted.Reset done	17:40:00	17:50:00	
7	CHP	Cc-39 SCR-6	B/C not running	PLC recycled and tested okay	18:24:00	18:40:00	
8	CHP	Cc 105 SCR-10	Slew not working	Wrong complaint	20:00:00	20:25:00	
9	CHP	Cc-44	Reported tripped	OLR acted.Reset done	21:05:00	21:10:00	
10	CHP	Cc-117	Reported tripped	OLR acted.Reset done	19:00:00	19:30:00	
11	CHP	CC-51 MPD	Reported tripped	OLR acted.Reset done(7 times)	15:28:00	18:20:00	
12	WT	OP-2	Reported not moving	D-3 tripped.Reset done	17:05:00	17:15:00	