



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 29/09/2025

Shift: C

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 16	OLR ACTED	RESET	02:00:00	02:10:00	
2	OHP	co 67	olr acted	reset	22:45:00	22:55:00	
3	OHP	CO 34A	MOTOR REPLACEMENT DONE	CHECKED AND GIVEN CLEARENCE AT 1 AM	22:00:00	01:00:00	
4	OHP	VF 15A	OLR ACTED	RESET	01:10:00 22:30:00	01:20:00 22:45:00	
5	OHP	SCR 5 ON CC 33	LT M1, M3 , M6 TRIPPING DUE TO TRACK JAMMING	INFORMED TO OPERATION	05:00:00	05:20:00	
6	OHP	BRC ON CO 34	CT DRIVE TRIPPED	RESET	00:00:00	00:15:00	
7	OHP	TBS ON CO 20	AFTER DNW CLEARENCE	MACHINE CHARGED, CHECKED	22:00:00	03:00:00	
8	OHP	CO 35	OLR ACTED	RESET	00:10:00 01:20:00	00:15:00 01:30:00	
9	CHP	CC 125	OLR ACTED	RESET	01:00:00	01:10:00	
10	CHP	SCR1 ON CC36	LUFF OLR ACTED	RESET	02:15:00	02:30:00	
11	CHP	SCR 10 ON CC 105 B/C	O/P GENERATING BUT RELAY NOT PICKING UP DUE TO ELECTRICAL INTERLOCK PROBLEM	CONNECTIONS TIGHTENED THEN OK	03:45:00	04:15:00	
12	CHP	SCR 3 ON CC 40 LT	PCRD O/T ACTED	RELEASED	05:20:00	05:40:00	
13	CHP	CC 51	FEEDING COVEYOR MPD ACTED	RESET	01:20:00	05:30:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 29/09/2025

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	CC 51 RED	MECH BRS (JOD) ACTED	INFORMED TO OPRN	04:35:00	04:50:00	
15	WT	OP5 ,6 NOT MOVING	LC 2A INCOMER 1 TRIPPED	MADE IT ON	01:35:00	01:50:00	
16	IOSA	TBS	PCRD O/T ACTED	RELEASED	23:00:00	23:15:00	