



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 24/10/2025

Shift: C

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	cO 29	olr acted	reset	22:50:00	22:55:00	3 times
2	OHP	CO 26	olr acted	reset	03:30:00	03:40:00	
3	OHP	TBS on CO 19	LT not working,M3 motor tripped	reset	00:40:00	00:55:00	
4	OHP	CO 6A	EMERGENCY Stop in panel,power mains ,MCCB magnet and conveyor is in off	power mccb ,magnet ,conveyor and mains made on	23:30:00	23:45:00	may be not normalised after PPM in general shift
5	CHP	CC 35 SCR 3	LT not working,m4,8,9 mpcb trips track jamming	made it on,informed operation	02:25:00	02:40:00	
6	CHP	CC 45	motor not running,olr acted	reset	02:40:00	02:50:00	
7	CHP	CC 107	olr acted, mpd trips	reset	04:20:00	04:30:00	
8	CHP	CC 54	olr acted	reset	04:52:00	04:57:00	
9	CHP	CC 38 SCr 6	Lt not taking place,M1 and M2 mpcb trips	made it on	04:10:00	04:20:00	
10	WT	AF 4(O)	trips in ground fault	ground fault setting B306 set 0,after that tripped in speed deviation fault	05:40:00	06:20:00	informed operation and mechanical ,to be checked pan