



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 06/05/2025

Incharge(s): K SANKARA RAO

Shift: A

| Sl No | Area | Equipment     | Problem                                  | Action                | From     | To       | Remarks |
|-------|------|---------------|--|-----------------------|----------|----------|---------|
| 1     | OHP  | WOBR ON CO 25 | B/C NOT RUNNING ZS CAGE STUCK WITH STONE | REMOVED               | 07:45:00 | 08:00:00 |         |
| 2     | OHP  | CO 35         | OLR ACTED                                | RESET                 | 08:00:00 | 08:15:00 |         |
| 3     | OHP  | CO 51         | STOPPING ON ZS BELT OFFCENTRING          | INFORMED TO OPERATION | 07:00:00 | 07:15:00 |         |
| 4     | CHP  | CC 117        | OLR ACTED                                | RESET                 | 08:10:00 | 08:15:00 |         |
| 5     | CHP  | CC 44         | OLR ACTED                                | RESET                 | 13:30:00 | 13:35:00 |         |
| 6     | CHP  | CC40 SCR 6    | TUL C/S NOT WORKING PROBE WIRE GOT CUT   | JOINT DONE            | 07:15:00 | 07:35:00 |         |
| 7     | CHP  | CC40          | OLR ACTED                                | RESET                 | 10:00:00 | 10:15:00 |         |
| 8     | CHP  | CC 107        | BRS NOT WORKING                          | SENSORS CLENED OK     | 11:00:00 | 11:15:00 |         |