



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 22/06/2025

Shift: B

Incharge(s): Lal Singh, Arnab Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR on CO 25	Slew not working , motor OLR acted	OLR reset done	14:15:00	14:30:00	
2	OHP	BRC on CO 30	BC not working , OLR acted	reset done	15:47:00 16:09:00	16:00:00 16:12:00	
3	OHP	VS 1A	OLR acted	reset done	18:30:00	18:45:00	
4	CHP	CC 111 , S-3	BC signal missing	Checked signal okay	14:55:00	15:05:00	
5	CHP	CC 32 , SCR 5	LT not working	Local emergency PB acted , released then ok	15:25:00	15:35:00	
6	CHP	CC 38 , SCR 3	Slewing not working	Slew Limit acted due to coal jamming . Inform to operation	15:50:00	16:05:00	
7	CHP	CC 34 , SCR 2	LT not working due to overtension acted	Overtension released, second time drive tripped and reset done	17:25:00 18:20:00 19:50:00 21:15:00	17:35:00 18:30:00 20:05:00 21:25:00	Drive tripping in OHF fault
8	CHP	CC 39 , SCR 7	Slew not working	Spider break fail alarm. Spider reset	17:27:00	17:35:00	
9	CHP	CC 33 , SCR 4	LT reverse not working	limit acted , cleaned and tested ok	18:20:00	18:45:00	
10	CHP	CC 39 , SCR 7	BC not working	OLR acted , reset done	19:15:00	19:30:00	
11	CHP	CC 219	Tripped in overload	reset done	21:40:00	21:50:00	
12	CHP	CC 54	Tripped on overload ( 3 times)	reset done	20:55:00	21:35:00	



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 22/06/2025

Shift: B

Incharge(s): Lal Singh, Arnab Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
13	CHP	CC 31	Drive chute Flap gate motor tripped	reset done	17:30:00	17:35:00	
14	WT	OP 9	Communication problem	Kept in local mode and moved , again kept in remote	14:00:00	14:30:00	
15	WT	OT 5	LS 4 acted	released	15:40:00	15:45:00	
16	WT	OP 7	Not moving	Individual breaker tripped in LC . Made on	16:30:00	16:40:00	
17	WT	OP 3	D 4 gear box problem	Informed mechanical and operation. Mechanical on work and lighting given	17:30:00	18:00:00	