



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

Date: 19/08/2025

Area: WT

Equipment	Job
CP 3	D2 motor changing and testing done with New motor ,stator cantactor kit replacd
OP 4 and 6	After rake maintenance done