



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 27/05/2025

Area: OHP

Equipment	Job
rsc0-9a,rsc0-6a,co-14b,13a, iosa interfacing DI bits	io bits of respective feeders including their position bits have been relocated as per new chart available at LC3 rio location.
co-13a,14a,14b,rsc0-6a	motor side vibration inspection is done and recorded.
co-10a,rsc0-1a,rsc0-2a,rco-6a,vs-1 panels	apn side and motor side running inspection is done, abnormal sound has been observed from rsc0-2a belt drive gearbox, informed mechanical.