



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 18/08/2025

Incharge(s): Amit Roy

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC on CO34	Reported pump stopping immediately	mechanical problem oil getting leak	06:20:00	06:30:00	informed to mechanical
2	OHP	BRC on CO-34	Reported hydraulic pump stopping	Charge pressure problem	08:40:00	09:00:00	informed to mechanical
3	OHP	BRC on CO-30	Reported LT not taking place	Drive tripped.Made on	09:15:00	09:25:00	
4	OHP	BRC on CO-31	Reported LT not taking place	M6 tripped.Reset done	11:00:00	11:20:00	
5	OHP	BRC on CO-28	Reported LT brakes not opening	Checked and found LT brake supply MPCB in off condition.Made on and tested okay	13:15:00	13:35:00	
6	OHP	TT-2 ON CO-21	Reported indication missing	CJD box fallen.Bypassed and then restored	09:45:00	10:00:00	
7	OHP	CO-12(C/D)	Reported tripped	OLR acted(2times).reset done	12:20:00	12:35:00	
8	OHP	TT2	Reported not moving	OLD joint opened.Temporary joint done	13:30:00	13:45:00	Permanent joint to be done
9	CHP	CC-111 SCR-8	B/C not starting	Wrong complaint	07:00:00	07:15:00	
10	CHP	CC-39 S-1-	slew not working	Coal jamming near limits.Cleaned and tested okay	07:05:00	07:25:00	
11	CHP	CC-33 SCR-4	Luff not working	main contactor problem.changed and tested okay	08:40:00	10:30:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 18/08/2025

Incharge(s): Amit Roy

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
12	CHP	CC-35 scr-1	Lt not working	OT acted.released and tested okay	08:55:00	09:10:00	Track jamming informed to operation
13	CHP	CC-34 SCR-2	LT not working	M2 tripped.reset done	11:30:00	11:45:00	Track jamming informed to operation
14	CHP	CC-112 S-3	Reported no power	I/C tripped.made on	13:40:00	14:00:00	LT track jamming informed to operation
15	CHP	CC-29	Reported CJD acting	Cjd cable earth fault found. cable insulated and i/O rack fuse replaced	13:20:00	13:30:00	
16	CHP	CC-111	Position indication not coming	Sensor cleaning done and fuse replaced at I/O rack	13:30:00	13:40:00	
17	CHP	CC-51	Reported ZSS acting	due to over material on belt	10:24:00 11:00:00 11:20:00	10:30:00 11:10:00 11:30:00	
18	CHP	CC-53(TT FG)	Reported Tripped	OLR acted.Reset done	09:35:00	09:45:00	
19	CHP	CC-130	ZSS acted	Due to belt snap	11:00:00	11:30:00	informed to operation
20	WT	OP-1	Reported not moving	Breaker tripped. Made on	11:00:00	11:30:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 18/08/2025

Incharge(s): Amit Roy

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
21	IOSA	OC-13A	Reported stopping on ZSS	ZSS cage problem.Bypassed and given clearance for rake clearing	13:50:00	14:00:00	informed to B shift to change cage after rake clearance