



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 15/11/2025

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 29	OLR ACTED	RESET	00:20:00	00:30:00	
2	OHP	VF1A	M1 MPCB TRIP	MADE IT ON	23:25:00	23:35:00	
3	OHP	CO 50	OLR ACTED	RESET	03:10:00	03:20:00	
4	OHP	WF 5	ZSS CAGE PROBLEM	REPLACED	03:25:00	03:55:00	
5	CHP	cc 54	OLR ACTED	RESET	00:25:00	01:10:00	5 TIMES
6	CHP	CC 51	FEEDING CONV MPD ACTED	RESET	01:35:00	02:05:00	2 TIMES
7	CHP	CC 117	OLR ACTED	RESET	04:45:00	05:00:00	
8	CHP	SCR 9 ON CC 104	YARD SIGNAL NOT COMING TO MACHINE DUE TO SCR 9 MACHINE SELECTED TO BOTH CC 104 AND CC214 YARD CONVEYORS	CC 214 MACHINE SELECTION SIGNAL DESELECTED THEN OK	03:00:00	05:00:00	NO DELAY
9	WT	CO4 CD NOT MOVING	POWER KEPT OFF	MADE IT ON	22:30:00	22:50:00	