



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 03/02/2026

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 36B	BRS NOT RESET DUE TO MATERIAL JAMMING	AFTER CLEANING THEN OK	22:35:00	22:45:00	
2	OHP	BRC ON CO 32	OIL LEVEL LOW DUE TO OIL LEAKAGE	INFORMED TO MECH	00:00:00	00:20:00	
3	CHP	CC 131	OLR ACTED	RESET	05:40:00	05:45:00	
4	CHP	CC 51	FEEDING CONV OLR ACTED	RESET	23:10:00	03:10:00	7 TIMES
5	CHP	CC 132	OLR ACTED	RESET	02:00:00	02:10:00	
6	CHP	CC 114	ZS ACTING DUE TO LOAD	AFTER CLEANING OK	23:35:00	23:55:00	
7	CHP	CC 203	OLR ACTED	RESET	01:30:00	01:40:00	
8	CHP	SCR 5 ON CC 32	B/C OLR ACTED	RESET	03:55:00	04:05:00	
9	CHP	SCR 5 ON CC 32	B/C STOPPING FREQUENTLY DUE TO BELT LOOSE	INFORMED TO MECH FOR BELT TENSION	05:30:00	05:45:00	