



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 12/08/2025

Area: CHP

Equipment	Job
CC-131	4 NO'S BELT SWAY SWITCHES KEPT IN CIRCUIT
CC-51 Tunnel	FG-112 area LDB ppm done and defective MCB replaced
Misc	5 no's 50w leds prepared and tested
SCR-7,SCR-5	Instrumentation switches ppm done
Misc	CM-18 panel preparation is under progress
CC-32	Running inspection done and defects rectified
cc-32,scr-5,cc-105,scr-7	ppm done