



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 14/08/2025

Area: WT

| Equipment | Job |
|--------------|--|
| OT 5 series | Panel and Motor side ppm done |
| OP 3 | D1 Over Load Relay checked ,found OK bypass removed and D4 kept in circuit after Mech. clearance |
| CP 4 | Trolley line checking done ,Middle and Bottom C - Clamps replaced,Bus bar adjusted @ 77 and 68 |
| CP 3 | After rake maintenance done, one lug replaced in D4 |
| OP 1,4 and 8 | After rake maintenance done |