



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 04/01/2026

Shift: B

Incharge(s): Nagendra Midde

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|----------------------------|---|----------------------------|----------------------|----------------------|----------|
| 1 | OHP | CO 3 | ZSS CAGE GOT TILTED AND PROBE DAMAGED | PROBE REPLACED | 19:00:00 | 19:30:00 | |
| 2 | OHP | TT2 | POWER CABLE OLD JOINT GOT OPENED INTERNALLY | PROPERLY CONNECTED THEN OK | 17:00:00 | 18:45:00 | |
| 3 | OHP | CO 26 | OLR ACTED | RESET | 17:50:00 | 17:55:00 | |
| 4 | OHP | CO 20 BRS | CONTROL FUSE DAMAGED IN I/O RACK | REPLACED | 20:10:00 | 20:20:00 | |
| 5 | OHP | CO 11A, CO 31A NOT RUNNING | TRIPPED IN 1-2 LBDS8 | MADE IT ON | 16:50:00 | 17:20:00 | |
| 6 | CHP | CP 4 | EMERGENCY STOP ACTED NEAR DEAD END | RELEASED | 20:00:00 | 20:15:00 | |
| 7 | CHP | CC 51 | FEEDING CONV MPD ACTED | RESET | 16:00:00 | 21:30:00 | 16 TIMES |
| 8 | CHP | CC 54 | OLR ACTED | RESET | 18:00:00 | 20:00:00 | 3 TIMES |
| 9 | CHP | CC 131 | OLR ACTED | RESET | 16:30:00 | 20:00:00 | 3 TIMES |
| 10 | CHP | CC 117 | OLR ACTED | RESET | 18:30:00 21:40:00 | 18:40:00 21:45:00 | |
| 11 | CHP | SCR 6 ON CC 39 SLEW | LIMIT ACTED DUE TO COAL JAMMING | INFORMED TO OPRN | 15:35:00 | 15:45:00 | |
| 12 | CHP | SCR 8 ON CC 112 | B/C OLR ACTED | RESET | 17:25:00 | 17:40:00 | |
| 13 | CHP | SCR 9 ON CC 104 LUFF | MPCB TRIP | RESET | 17:25:00 | 17:35:00 | |



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 04/01/2026

Incharge(s): Nagendra Midde

Shift: B

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|-----------|-----------|--------|----------|----------|---------|
| 14 | CHP | CC 32 | OLR ACTED | RESET | 21:00:00 | 21:10:00 | |