



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 27/05/2025

Area: WT

Equipment	Job
MIS	Earth pits inspection done for LC 1,9,10A and 10B and noted the status
OP 4 and CP 4	after rake maintenance done
OP 9	Parking zone, Revers End limit striker adjusted by heating the pipe
EOT Crane (C)	Bus bar cleaning done under the pads