



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 02/07/2025

Area: IOSA

| Equipment | Job |
|-----------------|--|
| AIR COMPRESOR-2 | VCU UNIT REMOVED FROM AIR COMPRESSOR-1 AND KEPT IN AIR COMPRESSOR-2 AND GIVEN CLEARANCE TO EnMD AFTER BREAKER CHECKING IN TEST POSITION. |
| OC-25A | PPM DONE ON MOTOR AND FIELD DEVICES. |
| OC-29A | FIELD DEVICES INSPECTION DONE. |
| INSPECTION | DONE ON OC-4A,5A,6A,7A,7B,7C,9A,11A,21A,23A,25A,29A CONVEYORS. DEFECTS RECORDED |
| LBDS-2 | HOUSEKEEPING DONE IN LBDS2 BLDG |