



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 12/10/2025

Incharge(s): K SANKARA RAO

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-29`	TRIPPED ON OLR	RESET DONE	19:00:00	19:15:00	
2	OHP	CO-111 CD	TRIPPED ON OLR	RESET DONE	20:00:00	20:10:00	
3	OHP	BRC ON CO 8A	BW-1 ZSS ACTED	BYPASSED	19:00:00	19:15:00	
4	OHP	BRC ON CO-32	LT SKEW ACTED	ADJUSTED WITH MECH	16:00:00	16:15:00	
5	CHP	cc-51	olr acted (2times)	reset done	20:15:00 20:30:00	20:20:00 20:42:00	
6	CHP	CC-51	MPD TRIP (3TIMES) DUE TO FEEDING CONVEYOR STOP	RESET DONE	20:30:00 20:55:00 21:15:00	20:35:00 21:00:00 21:20:00	
7	CHP	CC-104 SCR-9	ACB TRIPPED	RESET DONE	15:20:00	15:30:00	
8	CHP	SCR-8 CC-112	SLEW NOT WORKING	30 DEGREE LIMIT ACTED RELEASED	16:10:00	16:20:00	
9	CHP	SCR-2 CC-34	LT NOT WORKING .. PCRD OT ACTED	RELEASED	18:20:00	18:30:00	
10	CHP	CC-37 SCR-7	BC TRIPPED ON OLR	RESET DONE	20:15:00	20:30:00	
11	WT	OP-10	NOT MOVING D2 AND D3 TRIPPED	RESET DONE	18:00:00	18:15:00	