



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 29/06/2025

Incharge(s): Arnab Roy

Shift: A

| Sl No | Area | Equipment     | Problem  | Action   | From     | To       | Remarks  |
|-------|------|---------------|--|--|----------|----------|--|
| 1     | OHP  | CO 20         | BRS to be bypassed as per operation request due to belt pieces   | BRS bypassed   | 07:45:00 | 07:50:00 | again kept in circuit as per operation request |
| 2     | OHP  | CO 19         | BRS to be bypassed as per operation request due to belt hole   | BRS bypassed   | 08:45:00 | 08:55:00 | again kept in circuit as per operation request |
| 3     | OHP  | CO 29         | OLR acted  | reset done   | 09:15:00 | 09:20:00 |  |
| 4     | OHP  | BRC on CO 8A  | BC direction to be changed as per operation request due to material overload on belt bcz of belt loose and pully touching chute hood | BC direction changed   | 07:45:00 | 08:00:00 | again direction changed to original            |
| 5     | OHP  | BRC on CO 31  | CT not taking place  | operator cabin side limit stucked, made free   | 10:45:00 | 11:05:00 |  |
| 6     | CHP  | CC 33         | Not healthy , MPR tripped ( 2 times)   | reset done   | 09:30:00 | 09:50:00 |  |
| 7     | CHP  | CC 35 , SCR 1 | BW not running   | OLR acted , reset done   | 10:45:00 | 10:55:00 |  |
| 8     | CHP  | CC 35 , SCR 1 | LT not working   | Drive tripped , reset done. Also track jamming , informed to operation   | 11:00:00 | 11:10:00 |  |
| 9     | CHP  | CC 32 , SCR 5 | BC not running   | Stopped in zero speed. Found that material stucked in zss cage, also hole in belt . Informed to operation and mechanical | 12:00:00 | 12:10:00 |  |



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 29/06/2025

Incharge(s): Arnab Roy

Shift: A

| Sl No | Area | Equipment      | Problem           | Action                        | From     | To       | Remarks |
|-------|------|----------------|-------------------|-------------------------------|----------|----------|---------|
| 10    | CHP  | CC 105, SCR 10 | No drives running | Main breaker tripped, made on | 12:55:00 | 13:05:00 |         |
| 11    | CHP  | CC 44          | OLR acted         | reset done                    | 12:35:00 | 12:40:00 |         |
| 12    | CHP  | CC 35 , SCR 1  | Slew not working  | OLR acted , reset done        | 13:00:00 | 13:10:00 |         |
| 13    | CHP  | cc-114         | tripped on olr    | reset done                    | 13:55:00 | 14:00:00 |         |