



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 13/05/2025

Incharge(s): Lal Singh

Shift: A

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|-----------------|---|--|----------------------|----------------------|---------|
| 1 | OHP | CO-16 , 8A, 37A | REQUEST TO KEEP BRS IN CKT FROM OPR | KEPT IN CKT | 06:00:00 | 06:30:00 | |
| 2 | OHP | CO-35 | TRIPPED ON OVER LOAD | RESET DONE | 11:05:00 12:25:00 | 11:10:00 12:30:00 | |
| 3 | OHP | CO-28 BRC | BC NOT STARTING | CHUT SENSOR ACTED DUE TO STONE STUCK UP ... REMOVED | 12:20:00 | 12:40:00 | |
| 4 | OHP | TBS ON CO -7A | LT NOT WORKING | LT BREAKS NEEDS TO BE ADJUSTED INFORMED MECH | 10:00:00 | 10:15:00 | |
| 5 | OHP | CO-20 TBS | LUFFING AND LT NOT WORKING | LUFF TRIPPED DUE TO BREAK PROBLEM ... BREAKS ADJUSTED WITH MECH... LT DONE AFTER LUFFING RECLAIMING HEIGHT | 06:45:00 | 07:20:00 | |
| 6 | OHP | CO-77 | BELT SCALE OF CO-84 TO CO 77 BYPASS REQ | BYPASSED | 14:00:00 | 14:10:00 | |
| 7 | CHP | CC-107 | BRS KEPT IN CIRCUIT | DONE | 08:30:00 | 08:40:00 | |
| 8 | CHP | CC-38 SCR-3 | LT DRIVE AND MOTOR TRIPPED ON OVER LOAD | RESET DONE | 07:30:00 | 07:50:00 | |
| 9 | CHP | CC-105 SCR-10 | BC NOT RUNNING | OLR ACTED RESET DONE ... SMOKE OBSERVED FROM GEARBOX INFORMED TO MECHANICAL | 10:35:00 | 10:50:00 | |
| 10 | CHP | CC-32 SCR-5 | BC TRIPPED ON OVERLOAD | RESET DONE | 12:00:00 | 12:20:00 | |
| 11 | CHP | CC-34 SCR-2 | LT OVER TENSION ACTED | RELEASED | 12:10:00 | 12:30:00 | |