



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 15/02/2026

Shift: B

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC ON CO 31 LT	SELECTOR SWITCH IN LOCAL	CHANGED TO REMOTE	16:45:00	17:00:00	
2	OHP	TBS ON CO 5A LT NOT STOPPING	REV PB GOT STUCK	MADE IT FREE	18:20:00	18:30:00	
3	OHP	BRC ON CO 28	CT DRIVE TRIPPED	RESET	20:00:00	20:20:00	
4	CHP	CC 27 A POSITION ON CC 39	SENSOR PLATE BENT	ADJUSTED PROPERLY	14:30:00	14:45:00	
5	CHP	CC 51	FEEDING CON OLR ACTED	RESET	16:15:00	20:00:00	4 TIMES
6	CHP	CC 117	OLR ACTED	RESET	17:30:00	17:45:00	
7	CHP	CC 216	OLR ACTED	RESET	14:25:00	14:30:00	
8	CHP	SCR 7 ON CC 104	ACB TRIP IS OPERATED IN IN OPERATOR CABIN	ACB MADE ON	15:35:00	15:45:00	
9	CHP	SCR 7 ON CC 104 LT	PCRD O/T ACTED	RELEASED	17:05:00	17:15:00	
10	CHP	CC 31	OLR ACTED	RESET	18:15:00	19:10:00	3 TIMES
11	CHP	CC 108	OLR ACTED	RESET	20:15:00	20:20:00	