



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 23/08/2025

Incharge(s): V Balaji Naik, Saurabh Kumar Yadav

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO12 carriage	MPCB trip	Reset done	15:00:00 17:00:00	15:15:00 17:15:00	
2	OHP	WOBR on CO29	BC olr acted	Reset done	16:55:00	17:15:00	
3	OHP	TT2	Double indication on CO21 and CO8a	CO8a bit removed in IO rake	21:25:00	21:35:00	
4	CHP	CC51	MPD trip 7 times	Reset done	20:00:00	21:40:00	
5	CHP	SCR7 on CC39	Lt not working found motors got tripped due to jaming	Reset and made on	16:05:00	16:15:00	
6	CHP	SCR6 on CC38	LT not working found drive trip	Reset done	16:10:00	16:20:00	
7	CHP	SCR1 on CC35	BW trip	reset done	17:55:00	18:10:00	
8	CHP	SCR5 on CC32	Luffing not working found filter clog 3 problem	Informed to mechanical and bypassed	20:00:00	20:15:00	
9	CHP	SCR10 on CC105	LT not working M2 motor trip	Reset done	20:15:00	20:35:00	
10	CHP	SCR1 on CC35	Lt not working due to track jaming	Informed operation for cleaning	20:35:00	20:45:00	