



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 08/08/2025

Shift: C

Incharge(s): Amit Roy,K SANKARA RAO

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|----------------|--|-----------------------------------|----------|----------|---------|
| 1 | OHP | RSCO-2A(B/D) | REPORTED STOPPING ON ZSS CHECKED PROBE DAMAGED | ZSS PROBE REPLACED THAN OK | 01:45:00 | 02:30:00 | |
| 2 | OHP | CO-10A | REPORTED RED OLR ACTED | OLR RESET DONE | 03:30:00 | 03:40:00 | |
| 3 | OHP | RSCO-10A (C/D) | NOT MOVED CHECKED OLR ACTED | RESET DONE | 04:05:00 | 04:15:00 | |
| 4 | OHP | CO-26 | REPORTED RED OLR ACTED | RESET DONE | 04:30:00 | 04:40:00 | |
| 5 | OHP | WOBR ON CO-29 | B/C STOPPING ON ZSS CHECKED ZSS PROBE WIRE GOT CUT | ZSS PROBE WIRE JOINT DONE THAN OK | 04:40:00 | 05:00:00 | |
| 6 | OHP | CO-35 | REPORTED RED OLR ACTED | RESET DONE | 05:00:00 | 05:10:00 | |
| 7 | OHP | RSCO-1A(C/D) | NOT TAKING PLACE OLR ACTED | RESET DONE | 23:55:00 | 00:05:00 | |
| 8 | OHP | CO-11(C/D) | NOT TAKING PLACE CHECKED OLR ACTED | RESET DONE | 23:45:00 | 00:00:00 | |
| 9 | OHP | CO-29 | REPORTED RED OLR ACTED | RESET DONE | 23:05:00 | 23:15:00 | |
| 10 | CHP | CC-29 F/G | REPORTED NOT MOVING OLR ACTED | RESET DONE | 22:55:00 | 23:05:00 | |
| 11 | CHP | CC-54 | REPORTED RED OLR ACTED (3TIMES) | RESET DONE | 23:30:00 | 00:15:00 | |
| 12 | CHP | CC-114 | STOPPING ON ZSS DUE TO BELT SNAP | INFORM MECHANICAL | 04:10:00 | 04:30:00 | |
| 13 | CHP | CC-116 | STOPPING ON ZSS CHECKED MECHANICAL PROBLEM | INFORM MECHANICAL | 01:30:00 | 01:50:00 | |
| 14 | CHP | CC125 | Reported not healthy | OLR acted. reset done | 02:05:00 | 02:15:00 | |