



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 01/01/2026

Area: CHP

Equipment	Job
JH C 1 , C 3	Hoist and LDB panels maintenance was done
LC 2 to LBDS 1	Cable continuity checked and found ok
CC 113	BRS sensors replaced and kept in ckt
JH C212	Burnt sump pump removed and submersible pump provided
S 2	5 nos 30W LED fixtures provided
Coal complex	Rooms cleaning done
SCR 6	Damaged cable trays welded and cable dressing done.LT end limit sensor replaced and tested