



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 26/06/2025

Shift: B

Incharge(s): G Eswara Rao

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	brc on co 34	bw 1 zss acting/	zss module replaced then tested ok	16:20:00	16:45:00	
2	OHP	co 45	reported red/mpcb tripped	checked and found motor got burnt/	19:30:00	20:00:00	motor replacement work is going on
3	OHP	rsco 10a	b/d tripped on olr	reset done	17:15:00	17:25:00	
4	OHP	tt 1 on co 21	chute position sensor got damaged	bypass done	21:00:00	21:10:00	
5	OHP	tbs on co 22	chute vibrator motor not working/olr acted	reset done	15:35:00	16:00:00	
6	OHP	co 84	tripped on olr 4 times	reset done	17:10:00	18:15:00	
7	OHP	co 84	belt scale bypass removed	for operation request	19:30:00	19:35:00	
8	OHP	brc on co 30	ct not working/chain fallen	informed to operation	21:20:00	21:45:00	
9	OHP	brc on co 34	bw 1 zss acting/	zss bypassed at module	21:00:00	21:15:00	
10	CHP	cc 131	tripped on olr 2 times	reset done	17:05:00 17:30:00	17:10:00 17:35:00	
11	CHP	cc117	tripped on olr	reset done	20:10:00	20:30:00	
12	CHP	cc 51	tripped on olr	reset done	15:50:00	16:00:00	
13	CHP	cc 51	belt sway acted due to off centring	inform to ope. and mech	19:50:00	20:00:00	
14	CHP	cc 114	brs bypassed at i/o rack	for operation requirement	19:50:00	20:00:00	
15	CHP	scr 10 on cc105	yard conv. interlock zss cage problem	cage replaced then ok	14:15:00	14:50:00	



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 26/06/2025

Incharge(s): G Eswara Rao

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
16	CHP	cc 105.,cc104	bss acted/qac 5 mcb tripped at plc panel	mcb made on	17:00:00	17:15:00	
17	CHP	cc111	brs acted	reset done	17:55:00	18:05:00	
18	CHP	scr 6 on cc40	It not taking place/pcrd tension acted	tension released	18:30:00	18:40:00	