



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 12/08/2025

Incharge(s): Lal Singh

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-11	TRIPPED ON OLR	RESET DONE	23:00:00	23:08:00	
2	OHP	CO-35	TRIPPED ON OVER LOAD	RESET DONE	04:15:00	04:20:00	
3	OHP	CR-2A	STOPPED ON ZSS	ZSS TARGET DAMAGED ... TARGET WELDED DONE MY MECH	00:30:00	01:00:00	
4	CHP	CC-26A	TRIPPING ON EARTH FAULT	MEGGERING DONE IR VALUE 0 ... SPARE MOTOR IS READY	22:50:00	06:00:00	
5	CHP	CC-125	TRIPPED ON OLR	RESET DONE	01:08:00	01:20:00	
6	CHP	CC-44	TRIPPED ON OLR	RESET DONE	03:49:00 04:00:00 04:10:00	03:52:00 04:05:00 04:15:00	
7	CHP	CC-34 SCR-2	SLEW DRIVE TRIPPED ON OVER LOAD	RESET DONE	03:58:00	04:10:00	
8	CHP	CC-51	MPD TRIPPED ON OL	RESET DONE (FEEDING YARD STOPPING)	00:25:00 01:20:00 04:45:00	00:30:00 01:25:00 04:50:00	
9	CHP	CC-54	TRIPPED ON OL	RESET DONE	00:45:00	00:50:00	
10	WT	CO-2	TRIPPED ON OLR	RESET DONE	04:15:00 05:15:00 05:30:00	04:20:00 05:20:00 05:35:00	