



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 04/07/2025

Incharge(s): G Eswara Rao

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 14	zss acting due jamming	inform to operation	08:45:00	09:00:00	
2	OHP	tbs on co 22	bc not running/no power and smoke observed from pcrd cable on the drum	H T power kept off at i/o panel cable placement is going on by GSHIFT AUXILARY POWER TAKEN FROM BRC ON CO 31	11:30:00	13:30:00	old joint got flashover /inform to dnw
3	OHP	brc on co 28	It not taking place/pcrd guide chain problem	inform to operation and mech.	07:30:00	07:45:00	
4	OHP	brc on co 8a	bc not running/stop pb operated at cabin side	pb released then ok	07:45:00	08:00:00	
5	OHP	vs 2a	tripped on olr due to jamming	reset done	09:30:00	09:40:00	
6	OHP	vs 4	tripped on olr	reset done	12:05:00	12:10:00	
7	OHP	co 15a	tripped on olr	reset done	11:30:00	11:40:00	
8	OHP	cscr 5 on cc32	bc not running/olr acted	reset done	11:10:00	11:20:00	
9	CHP	scr 9 on cc104	slewing problem C SHIFT pending/plc error EB03 FAULT	PLC POWER RECYCLED THEN OK	06:00:00	07:00:00	
10	CHP	CC113A	PC ACTED	not resetting	12:50:00	13:00:00	checking going on
11	CHP	TT ON CC29	flap gate not working/mpcb tripped	mpcb made on	13:05:00	13:15:00	
12	CHP	cc 52	stopped while running/micro plc not working and c/s out control cable earth fault.	c/s cable earth fault isolated then ok/	10:15:00	11:00:00	vfd not working and changed to dol
13	CHP	cc 131	tripped on olr	reset done	08:00:00	08:10:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 04/07/2025

Incharge(s): G Eswara Rao

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	cc 53	bss acted/not getting reset	bypassed at i/o rack	13:20:00	13:30:00	
15	CHP	cc 33	tripped on olr/ due jamming	reset done 6times	07:55:00	13:35:00	
16	CHP	scr 5 on cc 32	tripped on mpcb	mpcb made on	08:30:00	08:40:00	
17	CHP	R1 oncc31	bc not running/olr acted	reset done	07:45:00	07:55:00	
18	CHP	CC 125	tripped on olr	reset done	10:50:00	10:55:00	
19	CHP	scr 4 on cc33	It not working/end limit acted	limit released then ok	12:55:00	13:20:00	
20	CHP	scr 5 oncc 32	bc zss acting due to belt hole	bc zss bypassed at i/o rack	11:20:00	11:30:00	