



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 07/07/2025

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 3A	HEALTHY STOPPING POSITION INDICATION PLUG DAMAGED	PLUG REPLASD	06:30:00	06:45:00	
2	OHP	TBS ON CO 20	L/LUFF NOT TAKING PLACE BRAKE PROBLEM	BRAKE ADJUSTED THAN OK	09:00:00	09:15:00	
3	OHP	BRC ON CO 34	B/C NOT RUNNING SELECTOR LOCAL MODE IN OPERATOR CABIN	KEPT IN REMOTE	09:30:00	09:50:00	
4	OHP	BRC ON CO 33M	NO POWER CHECKED E/STOP ACTED	RESET	13:30:00	13:45:00	
5	CHP	CC 26 F/G	MPCB TRIPPED	MADE ON	07:10:00	07:30:00	
6	CHP	CC 19	OLR ACTED	RESET	10:05:00	10:15:00	
7	CHP	CC 131	OLR ACTED	RESET	13:00:00	13:10:00	
8	CHP	CC 54	OLR ACTED(4TIMES)	RESET	07:50:00	08:40:00	
9	CHP	CC 111 S3	B/C NOT RUNNING MOD TRIP	RESET	06:30:00	06:40:00	
10	CHP	CC 33 SCR 4	LT NOT TAKING PLACE PCRD O/T ACTED	RELEASED	09:30:00 12:30:00	09:40:00 12:40:00	
11	CHP	CC 35 SCR 1	LT NOT TAKING PLACE DRIVE TRIP	RESET	09:40:00	09:50:00	
12	CHP	CC 111	BRS ACTING FREQUENTLY	SENSOR CLEANING THAN OK	09:50:00	10:00:00	
13	CHP	CC 32 SCR 5	LT NOT TAKING PLACE M3 MPCB TRIP	RESET	10:55:00 12:00:00	11:10:00 12:10:00	
14	CHP	CC 125	MPD TRIP	RESET	11:00:00	11:05:00	
15	WT	OP 2	D 5 OLR ACTED	RESET	13:20:00	13:40:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 07/07/2025

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
16	WT	OT1	NOT COMMING INTIONAL POSITION	LIMIT ADJUSTED	07:30:00	08:00:00	
17	WT	OP 2	NOT MOVING F AND R PARKING ZONE CONTACTOR NOT PICK UP	TEMPRARY BY PASSED AGAIN REMOVED	07:30:00	08:00:00	
18	IOSA	WOBR ON OC 18A	LT NOT TAKING PLACE END LIMIT ACTED DUE TO GRASS	RELEASED	13:30:00	13:45:00	
19	IOSA	WOBR ON OC18A	SLEW AND B/W NOT WORKING RF1 OIL LEVEL ACTEDD	LEVER RESET	06:30:00	07:30:00	