



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 25/01/2026

Incharge(s): Nagendra Midde

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 26	OLR ACTED	RESET	21:00:00	21:10:00	
2	OHP	BRC ON CO 34 LT	PCRD CONTACTOR GOT STUCK	MADE IT FREE	16:30:00	17:00:00	
3	CHP	CC 51	FEEDING CONV OLR ACTED	RESET	17:50:00	21:30:00	6 TIMES