



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 11/09/2025

Incharge(s): Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 9	olr acted	reset	02:15:00	02:20:00	
2	OHP	CO 58 (C)	mpcb tripped	made it on	03:45:00	03:50:00	
3	OHP	CO 11(c)	mpcb tripped	made it on	04:00:00	04:05:00	
4	OHP	CO 19	ZSS acted ,zss probe not working	probe replaced	03:00:00	03:50:00	
5	OHP	RSCO 9a	olr acted, due to jamming	reset	02:15:00	02:20:00	
6	OHP	CO 34 BRC	b/c tripped due overload,material jamming	informed operation	23:30:00	23:45:00	
7	WT	OT 3	D2 trips in encoder fault	reset	05:55:00	06:00:00	