



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 03/09/2025

Incharge(s): V Balaji Naik, Saurabh Kumar Yadav

Shift: A

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|----------------|--|-------------------------|----------|----------|---------|
| 1 | OHP | CO 26 | olr acted | reset | 07:00:00 | 07:10:00 | |
| 2 | OHP | CO 24 | olr acted | reset | 11:40:00 | 11:45:00 | |
| 3 | OHP | CO 87 | BRS not healthy, BRs cable got cut near take up pulley | brs cable jointing done | 12:15:00 | 12:40:00 | |
| 4 | OHP | CO 58 | not healthy ZSS acted, Probe wire got cut | re jointed | 12:30:00 | 13:00:00 | |
| 5 | OHP | TBS on CO 24 | Rb/c not running, olr acted | reset | 13:35:00 | 13:45:00 | |
| 6 | CHP | CC 40 SCr3 | slew not working, slew limit acted, jamming | informed operation | 06:30:00 | 06:40:00 | |
| 7 | CHP | CC 34 SCR 2 | LT not taking place, OT acted | OT released | 08:30:00 | 08:45:00 | |
| 8 | CHP | CC 201 and 203 | motor overload acted | reset | 10:10:00 | 10:20:00 | |
| 9 | CHP | CC 131 | overload acted | reset | 11:06:00 | 11:10:00 | |
| 10 | CHP | CC 51 | olr acted feeding conveyor stop | olr reset | 12:20:00 | 12:25:00 | |
| 11 | CHP | CC 28 | olr acted | reset | 07:25:00 | 07:30:00 | |