



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 17/06/2025

Area: WT

Equipment	Job
others	Coupling fixed to spare 37 kw slip ring motor
cp-3	Panel and motor side ppm done and found D-5 motor Lug broken replaced with new lug.
cp-1	Panel and motor side ppm done